


NO	DESCRIPTION	MATERIAL	Q'TY	SIZE	REMARKS
1	MOTOR	T.E.F.C	1SET	7.5HPx4P	
2	V-BELT	RUBBER	1SET	200R/T	
3	MOTOR SUPPORT	SS400	1SET	4t	H.D.G
4	REDUCER	FC	1SET	200R/T	
5	FAN BLADE	F.R.P	1SET	ø1800	
6	FAN STACK	F.R.P	1SET	ø1840	
7	ELIMINATOR	P.V.C	1SET	-	
8	NOZZLE PIPE	P.V.C or P.E	1SET	80A	
9	NOZZLE	P.P	1LOT	25A	
10	FILLER	P.V.C	1LOT	0.4t	
11	FILLER SUPPORT	SS400	1SET	4t	H.D.G
12	CASING(BODY)	F.R.P	1SET	5t	
13	LOUVER	EX/METAL	1LOT	200R/T	H.D.G
14	COLD WATER BASIN	F.R.P	1SET	5t	
15	LADDER	S.P.P.W	1SET	20A	
16	FOUNDATION	CON'C	1LOT	-	OUT OF SCOPE

SPECIFICATION DATA			LOADING DATA
1	CIRCULATING WATER FLOW	156M ³ /HR(200R/T)	SHIPPING WEIGHT 1140KG
2	NOMINAL CAPACITY	780,000Kcal/hr	
3	HOT WATER TEMPERATURE	37 °C	OPERATING WEIGHT 3050KG
4	COLD WATER TEMPERATURE	32 °C	
5	WET BULB TEMPERATURE	27 °C	

PIPE SPECIFICATION DATA			
NO	NAME	SIZE	CONNECTION
A	INLET PIPE	150A	FLANGE
B	OUTLET PIPE	150A	FLANGE
C	DRAIN PIPE	50A	SOCKET
D	AUTOMATIC MAKE UP	32A	SOCKET
E	MANUAL MAKE UP	32A	SOCKET
F	OVER FLOW	65A	SOCKET



NO.	REVISION	DATE	DRAWN	CHK'D	APP'R	REFERENCE DRAWING
△						
△						
△						
△						

DNT **D H Tech Co., Ltd.**
 디에이치테크(주)

Project NO. _____
 Scale M/S _____
 Unit mm _____
 Date 2005. 11. 17. _____
 Size A3 _____

Drawn _____
 Design _____
 Checked _____
 Approved _____

PROJECT : COOLING TOWER
 COUNTER FLOW TYPE.

TITLE :
DHG-CU-200

DWG. NO. _____

Rev. No. _____