DWG. NO. DCT-1000R



NO	DESCRIPTION	MATERIAL	Q'TY	SIZE	REMARKS
1	MOTOR	T.E.F.C	1 SET	30HPx4P	3ø/220/380/440V/60Hz
2	REDUCER	V-BELT	1 SET	1000R/T	B - 61" x 11EA
3	MOTOR BASE	SS400+H.D.G	1 SET		
4	FAN	F.R.P	1 SET	ø3600	8 BLADES
5	FAN BOSS	AL+ALLOY	1 SET	ø830	
6	UPPER BODY	F.R.P	16 PI		
7	TURN BUCKLE	SS400+H.D.G	10 EA		
8	SPRINKLER HEAD	AL+ALLOY	1 SET	300A	
9	SPRINKLER PIPE	P.V.C	1 SET	100A	
10	ELIMINATOR	F.R.P	1 SET	2^t	
11	CENTER BODY	F.R.P	16 PI		
12	FILLER	P.P	1 LOT	0.4^t	SQUARE TYPE
13	CENTER PIPE	S.G.P+H.D.G	1 SET	300A	
14	FILLER SUPPORT	SS400+H.D.G	1 SET		
15	SUPPORT	S.G.P+H.D.G	1 SET	40A	
16	LADDER	S.G.P+H.D.G	1 SET	20A	
17	UNDER BODY	F.R.P	16 PI		
18	STRAINER	SS400+H.D.G	1 SET		
19	SUCTION TANK	SS400+H.D.G	1 SET	ø483	
20	LEG	SS400+H.D.G	1 SET	65A	



DETAIL "B"



DETAIL "A"



BASE FOUNDATION



DAE HWA STANDARD WATER FLOW(LA-TYPE)

NOTE

1. FOUNDATION : R.F CONCRETE (OUT OF SCOPE)
2. F.R.P TOLERANCE IS ±20mm.
3. NET WEIGHT : 6529 KG
4. OPERATE WEIGHT : 18350 KG

NO.	REVISION	DATE	DRAWN	CHK'D	APP'R	REFERENCE DRAWING
△						
△						
△						
△						

D H Tech Co., Ltd.
디 에 이 치 테 크 (주)

Project NO.			
Scale	N/S	Drawn	
Unit	mm	Design	
Date	2003. . .	Checked	
Size	A4	Approved	

PROJECT : COOLING WATER SYSTEM

TITLE : ROUND TYPE COOLING TOWER 1000 R/T ASS'Y DWG.

REF. NO. RN373227FVP10001-001 Rev. No. 1