



DAE HWA STANDARD WATER FLOW(LA-TYPE)


NO	DESCRIPTION	MATERIAL	Q'TY	SIZE	REMARKS
1	MOTOR	T.E.F.C	1 SET	10HPx4P	3ø220/380/440V/60Hz
2	REDUCER	V-BELT	1 SET	350R/T	B - 32" x 7EA
3	MOTOR BASE	SS400+H.D.G	1 SET		
4	FAN	F.R.P	1 SET	ø2400	6 BLADES
5	FAN BOSS	AL+ALLOY	1 SET	ø395	
6	UPPER BODY	F.R.P	8 PI		
7	TURN BUCKLE	SS400+H.D.G	1 EA		
8	SPRINKLER HEAD	AL+ALLOY	1 SET	200A	
9	SPRINKLER PIPE	P.V.C	1 SET	75A	
10	ELIMINATOR	F.R.P	1 SET	2 ^t	
11	CENTER BODY	F.R.P	8 PI		
12	FILLER	P.P	1 LOT	0.4 ^t	SQUARE TYPE
13	CENTER PIPE	S.G.P+H.D.G	1 SET	200A	
14	FILLER SUPPORT	SS400+H.D.G	1 SET		
15	SUPPORT	S.G.P+H.D.G	1 SET	25A	
16	LADDER	S.G.P+H.D.G	1 SET	20A	
17	UNDER BODY	F.R.P	8 PI		
18	STRAINER	SS400+H.D.G	1 SET		
19	SUCTION TANK	SS400+H.D.G	1 SET	400A	
20	LEG	SS400+H.D.G	1 SET	32A	



DETAIL "B"



DETAIL "A"



BASE FOUNDATION

- NOTE**
1. FOUNDATION : R.F CONCRETE (OUT OF SCOPE)
 2. F.R.P TOLERANCE IS ±20mm.
 3. NET WEIGHT : 1966 KG
 4. OPERATE WEIGHT : 4000 KG

NO.	REVISION	DATE	DRAWN	CHK'D	APP'R	REFERENCE DRAWING
△						
△						
△						
△						

D H Tech Co., Ltd.
 디에이테크(주)

Project NO. _____

Scale	N/S	Drawn	
Unit	mm	Design	
Date	2003. . .	Checked	
Size	A4	Approved	

PROJECT :	COOLING WATER SYSTEM
TITLE :	ROUND TYPE COOLING TOWER 350 R/T ASS'Y DWG.
REF. NO.	RN373227FVP03501-001

