



DAE HWA TECH

## SPECIFICATION SHEET FOR COOLING TOWER

SHEET NO.

1 / 3

Project Name

COOLING WATER SYSTEM

**INFORMATION**

All data set forth herein is in accordance with definitions and standards Published by the Cooling Tower Institute.

Symbol \* = minimum information to be filled - in by customer, other items may be specified at customer's option.

**GENERATION**

SELECTION

INDUCED DRAFT WATER COOLING TOWER

TOWER MODEL

DHG-RO-40

TYPE

F.R.P ROUND(COUNTER FLOW) TYPE

**DESIGN & OPERATING CONDITIONS**\* Circulating Water Flow, M<sup>3</sup>/HR

31.2

\* Hot(inlet) Water Temp. °C

37

\* Cold(outlet) Water Temp. °C

32

Wet Bulb Temp. Inlet °C

27

Ambient Temp. °C

-

Relative Humidity %

-

Tower Pump Head, M

-

Nominal Capacity, Kcal/Hr

156,000

Drift Loss, % of circulating flow

0.01

Evaporation Loss(at design), %

0.83

\* Tower Site(ground level,roof,etc.)

GROUND

\* Elevation Above Sea Level, M

-

\* Tower Exposure

NONE

**PHYSICAL DETAILS**

Number of Cells

1

Upper Body, Piece

1

Center Body, Piece

1

Under Body, Piece

1

Overall Tower Dimension, DIA.(Φ)× H, mm

1395 × 2150

Water Basin Dimension, B.C.D(Φ), mm

1200

Access to Top of Tower

-

Shipping Weight, Kg

280

Operating Weight, Kg

490

DOC. NO.

REV.: A



DAE HWA TECH

SPECIFICATION SHEET FOR COOLING TOWER

SHEET NO.

2 / 3

Project Name

COOLING WATER SYSTEM

**MATERIALS OF CONSTRUCTION**

Frame work Members	
Casing	F.R.P 5t
Filler	P.P 0.4t
Filler Support	SS400+H.D.G
Drift Eliminators	-
Water Distribution - Type	Sprinkler Pipe
Material	P.V.C
Center Pipe	P.V.C
Suction Tank	-
Motor Support	SS400+H.D.G
Support Frame	-
Leg	-
Ladder	-

**WATER PIPING CONSTRUCTION**

Water Inlet	Number	1
	Size	80A
	Height	기초로부터 INLET 중심부까지 160mm
Water Outlet	Number	1
	Size	80A
	Height	기초로부터 OUTLET 중심부까지 160mm
Center pipe	Number	1
	Size	80A
Suction Tank	Number	-
	Size	-
Sprinkler	Number	1
	Size	80A
Sprinkler Pipe	Number	4
	Size	40A
Drain	Number	1
	Size	25A
Overflow	Number	1
	Size	25A
Auto. Make-up	Number	1
	Size	20A
Manual Make-up	Number	-
	Size	-

DOC. NO.

REV. : A



DAE HWA TECH

## SPECIFICATION SHEET FOR COOLING TOWER

SHEET NO.

3 / 3

Project Name

COOLING WATER SYSTEM

**MECHANICAL EQUIPMENT****FANS**

Number	1
Type	AXIAL FLOW
Manufacturer	DAE HWA TECH
Diameter(Φ). mm	800
Number of Blades	4
Blade Material	AL+ALLOY
Hub Material	-
Fan Speed, R.P.M.	1150
Air Volume, m <sup>3</sup> /min	280
Fan Total Efficiency(%)	65

**SPEED REDUCER**

Number	-
Type	-
Model	-
Manufacturer	-
Reduction Ratio	-
AGMA Mechanical H.P Rating	-
Service Factor at Rated H.P. of Driver	-
No. of Reductions	-

**DRIVE**

Number	1
Kind	SQUIRREL CAGE INDUCTION MOTOR
Type	T.E.F.C
Manufacturer	MAKER STD.
Full Load Speed, R.P.M	1200
Elec. Char - phase / cycles / volt	3/60/220/380/440 "F" CLASS, IP54
Rated H.P	1HP x 6P

**ADDITIONAL DATA**

DOC. NO.

REV.: A