



DRAIN 50A
 OVER FLOW 80A
 MANUAL MAKE-UP 40A
 AUTO MAKE-UP 40A
 INLET 200A
 OUTLET 200A




DAE HWA STANDARD WATER FLOW(LA-TYPE)


NO	DESCRIPTION	MATERIAL	Q'TY	SIZE	REMARKS
1	MOTOR	T.E.F.C	1 SET	10HPx4P	3/220.380.440V/60Hz
2	REDUCER	V-BELT	1 SET	300R/T	B - 32" x 7EA
3	MOTOR BASE	SS400+H.D.G	1 SET		
4	FAN	F.R.P	1 SET	2400	6 BLADES
5	FAN BOSS	AL+ALLOY	1 SET	395	
6	UPPER BODY	F.R.P	8 PI		
7	TURN BUCKLE	SS400+H.D.G	1 SET		
8	SPRINKLER HEAD	AL+ALLOY	1 SET	200A	
9	SPRINKLER PIPE	P.V.C	1 SET	75A	
10	ELIMINATOR	F.R.P	1 SET	2'	
11	CENTER BODY	F.R.P	8 PI		
12	FILLER	P.P	1 LOT	0.4'	SQUARE TYPE
13	CENTER PIPE	S.G.P+H.D.G	1 SET	200A	
14	FILLER SUPPORT	SS400+H.D.G	1 SET		
15	SUPPORT	S.G.P+H.D.G	1 SET	25A	
16	LADDER	S.G.P+H.D.G	1 SET	20A	
17	UNDER BODY	F.R.P	8 PI		
18	STRAINER	SS400+H.D.G	1 SET		
19	SUCTION TANK	SS400+H.D.G	1 SET	400A	
20	LEG	SS400+H.D.G	1 SET	32A	



DETAIL "B"



DETAIL "A"



BASE FOUNDATION

NOTE

- FOUNDATION : R.F CONCRETE (OUT OF SCOPE)
- F.R.P TOLERANCE IS +20mm.
- NET WEIGHT : 1854 KG
- OPERATE WEIGHT : 3880 KG

NO.	REVISION	DATE	DRAWN	CHK'D	APP'R	REFERENCE DRAWING
△						
△						
△						
△						

D H Tech Co., Ltd.
 디에이치테크(주)

Project NO.		
Scale	N/S	Drawn
Unit	mm	Design
Date	2003. . .	Checked
Size	A4	Approved

PROJECT : COOLING WATER SYSTEM

TITLE : ROUND TYPE COOLING TOWER
300 R/T ASS'Y DWG.

REF. NO. RN373227FVP03001-001