



DAE HWA TECH

SPECIFICATION SHEET FOR COOLING TOWER

SHEET NO.

1 / 3

Project Name

COOLING WATER SYSTEM

INFORMATION

All data set forth herein is in accordance with definitions and standards Published by the Cooling Tower Institute.

Symbol * = minimum information to be filled - in by customer, other items may be specified at customer's option.

GENERATION

SELECTION	INDUCED DRAFT WATER COOLING TOWER
TOWER MODEL	DHG-RO-150
TYPE	F.R.P ROUND(COUNTER FLOW) TYPE

DESIGN & OPERATING CONDITIONS

* Circulating Water Flow, M ³ /HR	117
* Hot(inlet) Water Temp. °C	37
* Cold(outlet) Water Temp. °C	32
Wet Bulb Temp. Inlet °C	27
Ambient Temp. °C	-
Relative Humidity %	-
Tower Pump Head, M	-
Nominal Capacity, Kcal/Hr	585,000
Drift Loss, % of circulating flow	0.01
Evaporation Loss(at design), %	0.83
* Tower Site(ground level,roof,etc.)	GROUND
* Elevation Above Sea Level, M	-
* Tower Exposure	NONE

PHYSICAL DETAILS

Number of Cells	1
Upper Body, Piece	4
Center Body, Piece	4
Under Body, Piece	4
Overall Tower Dimension, DIA.(Φ)× H, mm	3300 × 3480
Water Basin Dimension, B.C.D(Φ), mm	2938
Access to Top of Tower	LADDER
Shipping Weight, Kg	950
Operating Weight, Kg	1822

DOC. NO.

REV.: A



DAE HWA TECH

SPECIFICATION SHEET FOR COOLING TOWER

SHEET NO.

2 / 3

Project Name

COOLING WATER SYSTEM

MATERIALS OF CONSTRUCTION

Frame work Members	
Casing	F.R.P 5t
Filler	P.P 0.4t
Filler Support	SS400+H.D.G
Drift Eliminators	F.R.P
Water Distribution - Type	Sprinkler Pipe
Material	P.V.C
Center Pipe	S.G.P+H.D.G
Suction Tank	SS400+H.D.G
Motor Support	SS400+H.D.G
Support Frame	SS400+H.D.G
Leg	SS400+H.D.G
Ladder	S.G.P+H.D.G

WATER PIPING CONSTRUCTION

Water Inlet	Number	1
	Size	150A
	Height	기초로부터 INLET 중심부까지 170mm
Water Outlet	Number	1
	Size	150A
	Height	기초로부터 OUTLET 중심부까지 170mm
Center pipe	Number	1
	Size	150A
Suction Tank	Number	1
	Size	Φ 300
Sprinkler	Number	1
	Size	150A
Sprinkler Pipe	Number	6
	Size	65A
Drain	Number	1
	Size	40A
Overflow	Number	1
	Size	50A
Auto. Make-up	Number	1
	Size	25A
Manual Make-up	Number	1
	Size	25A

DOC. NO.

REV. : A



DAE HWA TECH

SPECIFICATION SHEET FOR COOLING TOWER

SHEET NO.

3 / 3

Project Name

COOLING WATER SYSTEM

MECHANICAL EQUIPMENT**FANS**

Number	1
Type	ADJUSTABLE PITCH AXIAL FLOW
Manufacturer	DAE HWA TECH
Diameter(Φ). mm	1800
Number of Blades	4
Blade Material	F.R.P
Hub Material	AL+ALLOY
Fan Speed, R.P.M.	502.9
Air Volume, m ³ /min	1050
Fan Total Efficiency(%)	65

SPEED REDUCER

Number	1
Type	V-BELT(B32" x 5EA)
Model	DCT-DHG-RO-150
Manufacturer	DAE HWA TECH
Reduction Ratio	3.48 : 1
AGMA Mechanical H.P Rating	-
Service Factor at Rated H.P. of Driver	1.2
No. of Reductions	2

DRIVE

Number	1
Kind	SQUIRREL CAGE INDUCTION MOTOR
Type	T.E.F.C
Manufacturer	MAKER STD.
Full Load Speed, R.P.M	1750
Elec. Char - phase / cycles / volt	3/60/220/380/440 "F" CLASS, IP54
Rated H.P	5HP x 4P

ADDITIONAL DATA

DOC. NO.

REV.: A