

 DAE HWA TECH	SPECIFICATION SHEET FOR COOLING TOWER	SHEET NO. 1 / 3
Project Name	COOLING WATER SYSTEM	
INFORMATION		
All data set forth herein is in accordance with definitions and standards Published by the Cooling Tower Institute. Symbol * = minimum information to be filled - in by customer, other items may be specified at customer's option.		
GENERATION		
SELECTION	INDUCED DRAFT WATER COOLING TOWER	
TOWER MODEL	DHG-RO-5	
TYPE	F.R.P ROUND(COUNTER FLOW) TYPE	
DESIGN & OPERATING CONDITIONS		
* Circulating Water Flow, M ³ /HR	3.9	
* Hot(inlet) Water Temp. °C	37	
* Cold(outlet) Water Temp. °C	32	
Wet Bulb Temp. Inlet °C	27	
Ambient Temp. °C	-	
Relative Humidity %	-	
Tower Pump Head, M	-	
Nominal Capacity, Kcal/Hr	19,500	
Drift Loss, % of circulating flow	0.01	
Evaporation Loss(at design), %	0.83	
* Tower Site(ground level,roof,etc.)	GROUND	
* Elevation Above Sea Level, M	-	
* Tower Exposure	NONE	
PHYSICAL DETAILS		
Number of Cells	1	
Upper Body, Piece	1	
Center Body, Piece	1	
Under Body, Piece	1	
Overall Tower Dimension, DIA.(Φ)× H, mm	720 × 1325	
Water Basin Dimension, B.C.D(Φ), mm	525	
Access to Top of Tower	-	
Shipping Weight, Kg	44	
Operating Weight, Kg	78	
DOC. NO.		REV. : A



DAE HWA TECH

SPECIFICATION SHEET FOR COOLING TOWER

SHEET NO.

2 / 3

Project Name

COOLING WATER SYSTEM

MATERIALS OF CONSTRUCTION

Frame work Members	
Casing	F.R.P 5t
Filler	P.P 0.4t
Filler Support	SS400+H.D.G
Drift Eliminators	-
Water Distribution - Type	Sprinkler Pipe
Material	P.V.C
Center Pipe	P.V.C
Suction Tank	-
Motor Support	SS400+H.D.G
Support Frame	-
Leg	-
Ladder	-

WATER PIPING CONSTRUCTION

Water Inlet	Number	1
	Size	40A
	Height	기초로부터 INLET 중심부까지 118mm
Water Outlet	Number	1
	Size	40A
	Height	기초로부터 OUTLET 중심부까지 118mm
Center pipe	Number	1
	Size	40A
Suction Tank	Number	-
	Size	-
Sprinkler	Number	1
	Size	40A
Sprinkler Pipe	Number	4
	Size	15A
Drain	Number	1
	Size	25A
Overflow	Number	1
	Size	25A
Auto. Make-up	Number	1
	Size	15A
Manual Make-up	Number	-
	Size	-

DOC. NO.

REV. : A



DAE HWA TECH

SPECIFICATION SHEET FOR COOLING TOWER

SHEET NO.

3 / 3

Project Name

COOLING WATER SYSTEM

MECHANICAL EQUIPMENT**FANS**

Number	1
Type	AXIAL FLOW
Manufacturer	DAE HWA TECH
Diameter(Φ). mm	400
Number of Blades	4
Blade Material	AL+ALLOY
Hub Material	-
Fan Speed, R.P.M.	1150
Air Volume, m ³ /min	48
Fan Total Efficiency(%)	65

SPEED REDUCER

Number	-
Type	-
Model	-
Manufacturer	-
Reduction Ratio	-
AGMA Mechanical H.P Rating	-
Service Factor at Rated H.P. of Driver	-
No. of Reductions	-

DRIVE

Number	1
Kind	SQUIRREL CAGE INDUCTION MOTOR
Type	T.E.F.C
Manufacturer	MAKER STD.
Full Load Speed, R.P.M	1200
Elec. Char - phase / cycles / volt	3/60/220/380/440 "F" CLASS, IP54
Rated H.P	1 / 4HP x 6P

ADDITIONAL DATA

DOC. NO.

REV.: A